DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: Land Development Services
ADDRESS: PO Box 5602 Statesville, NC APPLICATION DATE: 7-30-99 DATE EVALUATED: 8-17-99
PROPOSED FACILITY: 3 Bdrm House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .78
LOCATION OF SITE: Lot 10 Stonecrest Old Mt Rd (R) Compton Rd (L) SR 2702 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other Englebrook on Right
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	L 2-3%	0-24	SBK C	FI FS SP SLSPO					PS .3
		24-48+	SBK C/SAP RL	FR					
2	L 3-5%	0-36	SBK C	FI FR					PS .3
		36-48	SBK C/SAP RL	FR VFR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 SqFt	Same
System Type(s)	25% Reduction	Same @ 50%
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J. Potter
OTHER(S) PRESENT: _____