DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jack Ellege APPLICANT: Chris Davidson
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 3/15
PROPOSED FACILITY: 3BR/Crawl PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .46 Ac
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	4% Linear	0-15	scl wsbk	Fr SS SP SEXP					PS .3
		15-36	cl m/co	Fr SS SP SEXP					
		36-48	cl m/sbk	Fr SS SP SEXP					
2	4% Linear	0-7	Fill	—					PS .3
		7-20	sc g	Fr NS NP NEXP					
		20-27	scl wsbk	Fr SS SP SEXP					
		27-48	cl w/ma m/sbk	Fr SS SP SEXP					
3	6½% Linear	0-8	sc (2)	Fr NS NP NEXP					PS .35
		8-13	scl stony mr. wsbk	fr SS SP SEXP					
		13-30	cl m/co usbk	Fr SS SP SEXP					
		30-48	cl sol rock	Fr SS SP SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	350 Rdcd. Pump	250 Reduced Pump
Site LTAR	.35	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: B. A. Johnson
OTHER(S) PRESENT: _____