IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Martin DATE 3/24/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd to Kyles X Rd. T. L. then T. R. on 1335. Go to End of Rd. T. R. 2 nd Lot on L. S. R. No. _____

SUBDIVISION NAME Compton Park LOT NO. 7 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20,000 Sq ft

Character & Porosity of Soil Cecil Clay C 7 B2
Percolation Rate _____
Topography Slope to front & W. Side Low
Depth to Water Table None Noted
Rock or other impervious formations _____



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlan Lackey

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Lines are Deep.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3/24/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold