DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: Shannon Brown
ADDRESS: Orville Rd Statesville APPLICATION DATE: 10 Oct 99 DATE EVALUATED: 11-10-99
PROPOSED FACILITY: 3 Bd Rm MH PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: 3.57Ac
LOCATION OF SITE: 5th Old Mt Rd (L) Orville (R) Virgin on left Turn by ball PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other before Park
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2.3%	0-12	SAB C	FR	Typic Chromic 2 SY				U
		12-38	SAB C/	FR SS SP SEXT					
		38-48	SAB C	FR					
2	L 8.10%	0-12	GR CL						PS .3
		12-46	SAB C	FR S SP SEXT					
3	L 5.8%	0-18	SAB C	FR					PS .3
		18-48	SAB C	FR SS SP SEXT					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JC Cathey
OTHER(S) PRESENT: Owner