IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR G + O. Builders DATE 4-27-76 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION Compton Park

S. R. No. _____

SUBDIVISION NAME Compton Park LOT NO. 4 SECTION OR BLOCK NO. _____


House ✓ Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 2½ Acres

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slope to back of lot
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from downspouts and surface water should be diverted away from septic tanks & lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4-27-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold