IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tom Hutchins DATE 4-15-76 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION Compton Park off of old Mountain Rd.

S. R. No. _____

SUBDIVISION NAME Compton Park LOT NO. 3 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slopes to back of lot
Depth to Water Table Low
Rock or other impervious formations None

Lot Area 2½ Acres



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water should be diverted away from Tank & lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4-15-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold