IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Freeze DATE 10/18/76 PERMIT NO.

PHONE: Business Home

LOCATION Compton Park off of Old Mountain Rd


S. P. N.

SUBDIVISION NAME Compton Park LOT NO. 1 SECTION OR BLOCK NO.

House ✓ Mobile Home Business

No. Bedrooms 3 No. Bathrooms 2½ ✓
Garbage Disposal Unit Yes No
Auto. Dishwasher Yes ✓ No
Auto. Wash. Machine Yes ✓ No
Site Suitable Yes ✓ No

Lot Area 2½ Acres



Plot of System

Contractor Cecil Clary
Soil Type Slight Slope
Slope Low
Rock None

Septic Tank 1250 Gals.
Distribution Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ✓
Public

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY

COMMENTS: Well field should be put over Tank Holes for Maintenance Purposes. Tank approx. 3' Deep due to Slope out Downslope and surface water should be diverted away from both Tank & Lines.

CERTIFICATE OF COMPLETION BY C. A. Stevenson DATE 10/14/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

White Copy: Pink Owner's Copy: Gold

The proposed OUT BUILDING addition does not appear to impact the existing septic system.
**NOTE:

R. STEVE HENDRICK RS/SB
Date: APRIL 13, 2010
ICHD-Environmental Health Division