IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 150395 PIN# 4722560269 1216 DATE 11-6-08

OWNER OR APPLICANT ROBERT EVOY PHONE: Business 704-400-8450 Home 704-528-4838

ADDRESS 451 TRAVIS MOORE Farm Rd Statesville NC 28677

LOCATION OMO WEST @ TRAVIS MOORE Farm ON RT ACCESS From Historic Graveyard

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA 10 Acres SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. 1.3

Septic Tank: 1000 Gallons; STB _____ Date _____

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 600-1200 Linear Feet 300

No Lines 3 x 100' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: CONVENTIONAL 25% REDUCT

Repair System Description: PUMP 25% REDUCT

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Persons ____

☐ Business No. Employees ____

☐ Other _____

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: ① RAKE AND LIME TRENCH WALLS DUE TO SMEARING AND MICA FLAKES ② Install Lines On Contours And Maintain Setbacks ③ SEE Comments ON PERMIT. ④ Keep Well 100' Away From

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY LORNE COOK, R.S.

Comments:/Conditions: SYSTEM AND REPAIR.

AS BUILT SKETCH

The location of the proposed pool house/cabana addition does not appear to impact the existing septic system.

**NOTE: _____

REHS

Date: 11/17/10

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Robert E. Evoy date 12/11/08

Improvement Permit by: _____ date 11-6-08

Authorization to Construct by: _____ date 11-6-08

Installed by: _____

Operation Permit by: _____ date _____

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

1467
1780
920
1860
910
880
890
900
930
448
TROUTMAN FARM RD
DAVID DR
113
N
E
W
S
LEVATED AREA
48'
36'
3'x10'
3'x10'
2'x10'
15'
36'
FUTURE POOL
DRIVEWAY
130'
HOUSE STAKED OUT
ATIO SYSTEM FAILED
COMPLETELY. NEED
STUDENT TO TAKE
ATIO TANK
EXCEED 5%
FROM
DRAINLINES
CAN NOT
DEEP