HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: David L. Sharp OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 2-1-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Lippard Springs Phase III Lot # 69
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINERALOGY	
1	0-2%	0-3"	cl	gr.	1:1 / vfr	.1942 WETNESS CONDITION - P.S.
		3"-36"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE - 36"-↑
		36"-↑	saprolite			.1944 RESTRICTIVE HORIZON - NA
						.1945 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3
2	1-3%	0-4"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION - P.S.
		4"-42"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE - 42"-↑
		42"-↑	Saprolite / clay mix			.1944 RESTRICTIVE HORIZON - NA
						.1945 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3
3	2-4%	0-5"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION - P.S.
		5"-39"	c	abk	1:1 / fr	.1943/.1956 SAPROLITE - 39"-↑
		39"-↑	Saprolite / clay mix			.1944 RESTRICTIVE HORIZON - NA
						.1945 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3
4	1-3%	0-4"	cl	gr	1:1 / vfr	.1942 WETNESS CONDITION - P.S.
		4"-41"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE - 41"-↑
		41"-↑	Saprolite / clay mix			.1944 RESTRICTIVE HORIZON - NA
						.1945 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1945): P.S. SITE LONG-TERM ACCEPTANCE RATE: .3 gpd / ft²
OTHER FACTORS(.1946): SYSTEM TYPE:
EVALUATED BY: Michael R. Connell OTHER(S) PRESENT: David Sharp
COMMENTS:

DRAFT