DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ___ APPLICANT: Heritage Bldg. Co.
ADDRESS: 120 Hickory Point Dr Statesville APPLICATION DATE: 92899 DATE EVALUATED: 10 13 99
PROPOSED FACILITY: 3 Bdrm House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .62
LOCATION OF SITE: N old mtPel ⓛ Rumple Hill Lot is on Right before second St PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 5-6%	0-36	SAB C	FR					PS .3
		36-52	SAB C/SiCl	FR					
2	CC 2-5%	0-12	SAB CL	FR					PS .3
		12-48	SAB M C	FR ss sp sese					
3	L 5-6%	0-36	SAB CL	FR					PS .5
		36-52	SAB C	FR ss sp sese					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 Sq Ft	Same
System Type(s)	Conv Capacity	Same
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JC Potter
OTHER(S) PRESENT: ___