DRAFT

SHEET 1 OF 1

PROPERTY I.D.# 6-C-6-A

DATE 1-11-96

COUNTY IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT Heritage Bldg Co. OWNER AGENT ✓ PHONE 881-7135 / 528-6644

ADDRESS 120 Hickory Point Dr APPLICATION DATE 12-18-96 DATE EVALUATED 1-11-96

Statesville, NC 28677 PROPOSED FACILITY 3BR House w/C.S.

PROPERTY SIZE 125 x 225' 0.646 AC

LOCATION OF SITE Lippard Sprwss Sd Lot #65

WATER SUPPLY: Onsite Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1942 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (FT)	1943 SOIL TEXTURE	1943 SOIL STRUCTURE	1943 SOIL MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
	L 3%	0-48	C	SBK	Il / FI			.1942 Wetness Cond. S
								.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
	L 3%	0-48	C	SBK	Il / FI			.1942 Wetness Cond. S
								.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
	H 22%	0-48	C	SBK	Il / FI			.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

SUITABLE SPACE (.1945) S LIMITING FACTORS (.1946) None SOIL CLASSIFICATION (.1948) PS

SYSTEM TYPE(S) Conv. Gravity LONG TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²

EVALUATED BY Steve Fedrick OTHER(S) PRESENT Rick Dyson, Eric Dyson

COMMENTS

0007216