IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14008b PIN# 4722 695 036 . 053 DATE 8-13-07

OWNER OR APPLICANT Spear Builders for HABITAT for Humanity PHONE: Business 704-202-4964 Home

SITE ADDRESS 112 Allendale Cir. Troutman NC; 229 WINDING CEDAR DR.

LOCATION Old mountain Rd N TR Buffalo Shoals Rd TR Davidson Rd TR Winding Cedar on left

SUBDIVISION Davidson Woods BLOCK / SECTION 3 LOT 53 LOT AREA .69AC SITE CLASS. PS DESIGN FLOW 360gpd L.T.A.R. .25 gpd/ft2

Septic Tank: 1000 Gallons: STB Date

Pump Tank: 1000 Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 720 Linear Feet 240

No Lines 6 Trench Width 36" * Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: PPBPS pm

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Persons 6

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: * per plan specs

Comments:/Conditions: Approved a 42'4" x 42' House Box which includes decks & porches. 3 Bedroom 2 Bath approval. Maintain all setbacks and house fits entirely in 50' x 80' box that was permitted on IP.

INITIAL SITE SKETCH

See plan from Rollins Soil & Environmental Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 12-7-11

Improvement Permit by: date 8-13-07

Authorization to Construct by: date 12-7-11

Installed by: A-1 Backhoe

Operation Permit by: date 5-18-12

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

Pd $320 3-12-12 Dist for Intermediate Pedrow