DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: MAX SPEAR — APPLICATION DATE: 1/06
ADDRESS: ____ — DATE EVALUATED: 1/06
PROPOSED FACILITY: ____ — PROPOSED DESIGN FLOW (.1949): ____ — PROPERTY SIZE: ____
LOCATION OF SITE: DAVIDSON WOODS LOT 53 — PROPERTY RECORDED: Y
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut — TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P13 1	L 0-5%	0-13	BSCL GR	fi SSSP Sap					PS .3
		13-41	RC mFSBK	fri SSSP Sap	–	64"	–	–	
		41-64	RCL WFSBK	fi SSSP Sap					
				com. SAP					
2	10%	0-9	gr SL (UPPER)	fr SSSP					.25
		9-35	WK SBK CL	fr SSSP SAP	few brown & few black sap				
		35-58	WK SBK CL	fr SSSP	common-many yellow & few sap red				
3		0-6	gr LFR SL	fr SSSP					.25
		6-20	MOD MK SBK CL	fr SSSP	SAP common brown				
		20-57	WK-MOD SBK CL	fr SSSP	few brown				
4		0-12	gr sl	fr NS NP	BR				.3
		12-22	gr/WK SBK	SCL fr SSSP	RED				
		22-32	MOD SBK C	* fi SSSP	RED				
		32-58	WK SBK CL	fi SSSP	C - SAP				
				* very dru					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: ____
OTHER(S) PRESENT: ____

COMMENTS: ____