North Carolina - Department of Environment and Natural Resources - Division of Water Quality - Groundwater Section - 1636 Mail Service Center - Raleigh, NC 27699-1639 - Phone No. (919) 733-3221

WELL ABANDONMENT RECORD

WELL CONTRACTOR _____

WELL CONTRACTOR CERTIFICATION # _____

1. WELL USE (Check Applicable Box): Residential ☑ Municipal ☐ Industrial ☐ Agricultural ☐ Monitoring ☐ Recovery ☐ Heat Pump Water Injection ☐ Other ☐ If Other, List Use: _____

2. WELL LOCATION: (Show a sketch of the location on back of form.)
Nearest Town: Trotman County Iredell
Lippard Springs Subdivision Lot # 2 Old Mtn. Road.
(Road Name and Number, Community, Subdivision, Lot No.) Quadrangle No.

3. OWNER: Daniel Blankenship

4. ADDRESS: 128 Hager Point Ln. Mooresville, NC 28117

5. TOPOGRAPHY: draw, slope, hilltop, valley, flat (circle one)

6. TOTAL DEPTH: 605 DIAMETER 6"

7. CASING REMOVED:

feet	diameter
44	6"

8. DISINFECTION: NA
(Amount of 70% hypochlorite used:)

9. SEALING MATERIAL:


Neat Cement
bags of cement 40
gallons of water 40

Sand Cement
bags of cement _____
gallons of water _____

Other
Type material Dirt and sand
Amount 523 ft. from bottom of hole to bottom of casing

10. EXPLAIN METHOD EMPLACEMENT OF MATERIAL.
Poured in cement on top of dirt and sand.

WELL DIAGRAM: Draw a detailed sketch of the well showing total depth, depth and diameter of screens remaining in the well, gravel interval, intervals of casing perforations, and depths and types of fill materials used.



11. DATE WELL ABANDONED 6-21-01

I do hereby certify that this well was abandoned in accordance with 15A NCAC 2C, well construction standards, and that a copy of the record has been provided to the well owner.

Signature of person abandoning the well Daniel Blankenship Date 6-21-01

WELL LOCATION: Draw a location sketch on the reverse of this sheet, showing the direction and distance of the well to at least two (2) nearby reference points such as roads, intersections and streams. Identify roads with State Highway road identification numbers.

Submit original to the Division of Water Quality, Groundwater Section, one copy to the owner within 30 days from completion of abandonment.

GW-30 Revised 12/99