HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

(2)

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: Kenneth Dean OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 9-15-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Leppard Springs Lot # 23
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

| PROFILE # | .1940 LANDSCP POS./ SLOPE % | HORIZON DEPTH (IN.) | .1941 (a)(1) TEXTURE | .1941 (a)(2) STRUCTURE | .1941 (a)(3) MINEROLOGY | | |
|---|---|---|---|---|---|---|---|
| 6 | 8-10% L | 0-5" | l | gr | fr | .1942 WETNES CONDITION | - U 30" chroma II |
| | | 5"-30" | c | wsbk | fi | .1943/.1956 SAPROLITE | - NA |
| | | 30"-48" | c | Abk | chroma II fi mottles | .1944 RESTRICTIVE HORIZON | - U 30" chroma II |
| | | | | | | .1948 PROFILE CLASSIFICATION | - U (P.S. LPP) |
| | | | | | | PROFILE LTAR | - |
| 7 | 9-10% L | 0-7" | l | gr | fr | .1942 WETNES CONDITION | - P.S. chroma II 42" |
| | | 7"-42" | c | wsbk | fi | .1943/.1956 SAPROLITE | - NA |
| | | 42"-45" | c | Abk | chroma II fi mottles | .1944 RESTRICTIVE HORIZON | - P.S. 42" chroma II |
| | | | | | | .1948 PROFILE CLASSIFICATION | - P.S. |
| | | | | | | PROFILE LTAR | - .3 |
| 8 | 8-10% L | 0-4" | l | gr | fr | .1942 WETNESS CONDITION | - P.S. 40" chroma II |
| | | 4"-37" | c | wsbk | fi | .1943/.1956 SAPROLITE | - 40" P.S. |
| | | 37"-40" | c | Abk | relic mottling fi | .1944 RESTRICTIVE HORIZON | P.S. - 40" chroma II |
| | | 40"-48" | c/sap | Abk/m | chroma II fi mottling | .1948 PROFILE CLASSIFICATION | - P.S. |
| | | | | | | PROFILE LTAR | - .3 |
| 4 | | | | | | .1942 WETNESS CONDITION | - |
| | | | | | | .1943/.1956 SAPROLITE | - |
| | | | | | | .1944 RESTRICTIVE HORIZON | - |
| | | | | | | .1948 PROFILE CLASSIFICATION | - |
| | | | | | | PROFILE LTAR | - |
| 5 | | | | | | .1942 WETNESS CONDITION | - |
| | | | | | | .1943/.1956 SAPROLITE | - |
| | | | | | | .1944 RESTRICTIVE HORIZON | - |
| | | | | | | .1948 PROFILE CLASSIFICATION | - |
| | | | | | | PROFILE LTAR | - |

AVAILABLE SPACE (.1945) P.S SITE CLASSIFICATION (.1948): P.S SITE LONG-TERM ACCEPTANCE RATE: 3 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: Michael Dean OTHER(S) PRESENT: Jeff Dean
COMMENTS:

2

DRAFT

0 0 0 1 1 8