THIS PERMIT VOIDS PREVIOUS ISSUED 7-22-03

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 (M) MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13715 PIN# 4722-67-3473 4722-67-0480 DATE 1-18-07

OWNER OR APPLICANT DEAN R. MURDOCK PHONE: Business 704-528-5678 Home

ADDRESS P.O. BOX 185 TROUTMAN NC 28166-0185

LOCATION US 21 S, TR OLD MTN. ROAD TR RUMPUE HILL, TR LIPPARD SPRINGS CIRCLE LOT ON INSIDE CIRCLE,

SUBDIVISION LIPPARD SPRINGS BLOCK / SECTION LOT 141 LOT AREA 0.690 ACRE SITE CLASS PS DESIGN FLOW 480 L.T.A.R. 0.30 GPD/FT²

Septic Tank: 1000 Gallons; STB 794 Date 2-24-06

Pump Tank: Gallons; PT Date

Pump Make: Model EQ-M Serial No.

Nitrification Field: No Fields 1 Square Feet 1600 Linear Feet 400

No Lines FIVE Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% REDUCTION, GRAVITY

Repair System Description: 50% REDUCTION, LOW PRESSURE

Maintenance Agreement Required: ☐ Yes ☑ No

☑ Gravity ☐ Pressure

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community WELL

Comments:/Conditions:

Comments:/Conditions: SEPTIC TANK WITH MARKER INSTALLED USING RED "PolyLOK" FILTER

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN PREPARED BY ROLLANS SOIL & ENVIRONMENTAL SERVICES PROJECT NUMBER 01-1179

AS BUILT SKETCH

SYSTEM INSTALLED ACCORDING TO INITAL SITE SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

☐ Permit with plat valid without expiration ☑ Improvement Permit with site plan valid for sixty months

Signed: date 1/18/07

Improvement Permit by: STEVE HEDRICK date 1-18-07

Authorization to Construct by: date 10-31-07

Installed by: STEVE GRAVES

Operation Permit by: STEVE HEDRICK date 5-19-08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK