DEPARTMENT OF ENVIRONMENT
HEALTH & NATURAL RESOURCES — DRAFT
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D #: 6-C-6-A
DATE: 1-11-96
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG CO. — OWNER ___ AGENT: ✓ — PHONE: 881-7135 / 528-6644
ADDRESS: 120 HICKORY POINT CT. STATESVILLE, NC 28677
APPLICATION DATE: 12-18-96 — DATE EVALUATED 1-11-96
PROPOSED FACILITY: 3BR House w/ C.S.
PROPERTY SIZE: ~125 X 225' C.696 AC
LOCATION OF SITE: LIPPARD SPRINGS RD LOT #65
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

HORIZON	1942 LANDSCAPE POS. SLOPE(%)	1942 HORIZON DEPTH (IN)	1941 (1) TEXTURE	1941 (2) STRUCTURE	1941 (3)(4) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
A	L	0-42	C	SBK	1:1 / FI			.1942 Wetness Cond. S
B	3%	42-48	C/SAP	WSBK	1:1 / FR			.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
A	L	0-42	C	SBK	1:1 / FI			.1942 Wetness Cond. S
B	3%	42-48	C/SAP	WSBK	1:1 / FR			.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR
								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR

SUITABLE SPACE (.1941) S — OTHER FACTORS (.1946) NONE — SITE CLASSIFICATION (.1948) PS
SOIL TYPE CONV. GRADE/ — LONG-TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²
EVALUATED BY: STEVE HEDRICK — OTHER(S) PRESENT: RICK DYSON, ERIC DYSON
COMMENTS