DEPARTMENT OF ENVIRONMENT
HEALTH & NATURAL RESOURCES — DRAFT
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.# 6-C-6-A
DATE 1-11-96
COUNTY IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT HERITAGE BLDG CO. OWNER AGENT: ✓ PHONE: 881-7135 / 528-6644
ADDRESS 120 4 STORY POINT CT APPLICATION DATE: 12-18-96 DATE EVALUATED 1-11-96
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR House w/C.S.
LOCATION OF SITE LIPPARD SPRINGS RD LOT # 62 PROPERTY SIZE ~125 X 225' 0.646 AC
WATER SUPPLY: Private Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1942 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN)	1941 [1][1] TEXTURE	[1][2] STRUCTURE	[1][3] MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	N	0-36	C	SBK	1:1 / FI			.1942 Wetness Cond. S
	4%	36-48	C/SAP	WSBK	1:1 FR			.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
2	L	0-36	C	SBK	1:1 / FI			.1942 Wetness Cond. S
	6%	36-48	SiC/SAP	WSBK	1:1 / FR			.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

USABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS
SOIL TYPE CONV. GRUNTY LONG TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²
EVALUATED BY: STEVE FREDRICK OTHER(S) PRESENT: RICK DYSON, ERIC DYSON
COMMENTS