DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 6-C-6-A
DATE: 1-11-96
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG. CO.
ADDRESS: 120 HICKORY POINT CT. STATESVILLE, NC 28677
OWNER ___ AGENT: ✓ PHONE: 881-7135 / 528-6644
APPLICATION DATE: 12-18-96 DATE EVALUATED 1-11-96
PROPOSED FACILITY: 3BR House w/C.S.
PROPERTY SIZE: ~125 X 225' 0.696
LOCATION OF SITE: LAKEWOOD SPRINGS SD LOT # 59
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1940 LANDSCAPE POS./ SLOPE(%)	HORIZON DEPTH (IN)	.1941 (1)(2) TEXTURE	.1941 (1)(2) STRUCTURE	.1941 (1)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
	L 6%	0-48	C	SBK	1:1/FI			.1942 Wetness Cond. S
								.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
	L 6%	0-48	C	SBK	1:1/FI			.1942 Wetness Cond. S
								.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

SUITABLE SPACE (.1945): S OTHER FACTORS (.1946): NONE SITE CLASSIFICATION (.1948): PS
SOIL TYPE: CONV GRAVITY LONG-TERM ACCEPTANCE RATE(S): 0.3 GPD/FT²
EVALUATED BY: STEVE FEDRICK OTHER(S) PRESENT: RICK DYSON, ERIC DYSON
COMMENTS: