DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Heritage Bldg Co. APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/9/01
PROPOSED FACILITY: 3BR Home/Office PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .6
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot # 147 (#147)

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	6% Linear	0-4"	Sc	~~mSbk~~ fr SS SP SEH					PS .25
		4-23	cl	~~Abk~~ fi SP SEH					
		23-49	cl	~~mSbk~~ fi/m SS SP SEH					
2	6% Linear	0-4	Sc	~~mSbk~~ SEH					PS .25
		4-23	cl	~~Abk~~ SP SEH					
		23-32	cl/sc	~~wSbk~~ FFi SS SP SEH					
		32-48	Sc (G)						
3	4% Linear	0-2	Scl	wGr SP SS SEH					PS .3
		2-26	cl	Abk SP SEH					
		26-34	cl/sc	SS SP SEH					
		34-48	Sc (G) SS	SEH					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity	
Site LTAR	.25	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____