DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1

PROPERTY I.D #: 6-C-6-A
DATE: 1-11-96
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG. CO. OWNER AGENT: ✓ PHONE: 881-7735 / 528-6644
ADDRESS: 120 HICKORY POINT CT. APPLICATION DATE: 12-18-96 DATE EVALUATED 1-11-96
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR House W/C.S.
LOCATION OF SITE: LIPPARD SPRINGS SD LOT # 58 PROPERTY SIZE: ~125 X 225' 0.796 AC
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1940 LANDSCAPE POS / SLOPE(%)	HORIZON DEPTH (IN)	.1941 (1) TEXTURE	.1941 (2) STRUCTURE	.1941 (3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
	L	0-48	C	SBK	1:1 / FL			.1942 Wetness Cond. .5
	6%							.1943 Depth/.1956 Sapr. .5
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3
	L	0-48	C	SBK	1:1 / FL			.1942 Wetness Cond. .5
	6%							.1943 Depth/.1956 Sapr. .5
								.1944 Restrictive Hori. .5
								.1948 Profile Class. PS
								Profile LTAR 0.3
								.1942 Wetness Cond. .
								.1943 Depth/.1956 Sapr. .
								.1944 Restrictive Hori. .
								.1948 Profile Class. .
								Profile LTAR .
								.1942 Wetness Cond. .
								.1943 Depth/.1956 Sapr. .
								.1944 Restrictive Hori. .
								.1948 Profile Class. .
								Profile LTAR .

SUITABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS
SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²
EVALUATED BY: STEVE FEDRICK OTHER(S) PRESENT: RICK DYSON, ERIC DYSON
COMMENTS: