HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 10D-A-20 (50)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG. Co OWNER: ✓ AGENT: PHONE: 528-6644
ADDRESS: RT. 10, BOX 177-A APPLICATION DATE: 5/26/94 DATE EVALUATED: 5/26/94
STVL, NC. 28677 PROPOSED FACILITY: 3 BR HOUSE
PROPERTY SIZE: ~ 150'x 370'
LOCATION OF SITE: # 50 MEADOW OAKS
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ ✓ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 6.2	0-48	C	SBK	1:1/FI	.1942 WETNES CONDITION 5
						.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2						.1942 WETNES CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: RICK DYSON, MR. NEAL
COMMENTS:

DRAFT