DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: [illegible]

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: MAX SPEAR
ADDRESS:
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___
LOCATION OF SITE: DAVIDSON WOODS LOT 59
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut

APPLICATION DATE 1/06
DATE EVALUATED: 1/06
PROPERTY SIZE: ___
PROPERTY RECORDED: Y

TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1949 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
P5 1	L 5-10% out of system layout	0-11	BSCL WC	fri SSSPSmP					PS .25 to 45"
		11-33	RC MFSBK	fri SSSPSmP					
		33-45	RC/CL WFSBK	fri SSSPSmP	—	45"	4	45"	
		45-66	V Rock control SAP						
P6 2	L 8-10%	0-27	RC SBK	fri SSSPSmP					PS .3
		27-66	RCL WSBK	fri SSSPSmP	—	66"	—	—	
3	4 24 07	0-9	gr sl	fr sssp	Br				.3
		9-24	mo sbkc	fr sssp	Red				
		24-38	wk fsbk cl	fr sssp	Red f-sap				
		38-52	wk fsbk cl	fr sssp	f-c sap				
4		0-9	gr sl	fr sssp	Br				.3
		9-36	mo fsbk c	fr sssp	Red	few quartz			
		36-47	wk fsbk cl	fr sssp	Y/R c-sap				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

COMMENTS: ___