DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 6-C-6-A
DATE: 1-11-96
COUNTY: IREDELL

# SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG CO.
ADDRESS: 120 HICKORY POINT CT. STATESVILLE, NC 28677
OWNER ___ AGENT: ✓ PHONE: 881-7135 / 528-6644
APPLICATION DATE: 12-18-96 DATE EVALUATED 1-11-96
PROPOSED FACILITY: 3BR House w/C.S.
PROPERTY SIZE: ~125 X 225' 0.623
LOCATION OF SITE: LIPPARD SPRINGS RD LOT # 57
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

| PROFILE # | 1940 LANDSCP POS / SLOPE(%) | HORIZON DEPTH (in) | 1941 (1) TEXTURE | (2) STRUCTURE | (3) MINERALOGY | MATRIX COLOR | MOTTLE COLOR | OTHER PROFILE FACTORS |
|---|---|---|---|---|---|---|---|---|
| 1 | L 4% | 0-48 | C | SBK | 1:1 / FI | | | .1942 Wetness Cond. S |
| | | | | | | | | .1943 Depth/.1956 Sapr. S |
| | | | | | | | | .1944 Restrictive Hori. S |
| | | | | | | | | .1948 Profile Class. PS |
| | | | | | | | | Profile LTAR 0.3 |
| 2 | L 4% | 0-48 | C | SBK | 1:1 / FI | | | .1942 Wetness Cond. S |
| | | | | | | | | .1943 Depth/.1956 Sapr. S |
| | | | | | | | | .1944 Restrictive Hori. S |
| | | | | | | | | .1948 Profile Class. PS |
| | | | | | | | | Profile LTAR 0.3 |
| 3 | | | | | | | | .1942 Wetness Cond. - |
| | | | | | | | | .1943 Depth/.1956 Sapr. - |
| | | | | | | | | .1944 Restrictive Hori. - |
| | | | | | | | | .1948 Profile Class. - |
| | | | | | | | | Profile LTAR - |
| 4 | | | | | | | | .1942 Wetness Cond. - |
| | | | | | | | | .1943 Depth/.1956 Sapr. - |
| | | | | | | | | .1944 Restrictive Hori. - |
| | | | | | | | | .1948 Profile Class. - |
| | | | | | | | | Profile LTAR - |

SUITABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS
SYSTEM TYPE CHAMBERED GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²
EVALUATED BY: STEVE FEDRICK OTHER(S) PRESENT: RICK DYSON, ERIC DYSON
COMMENTS: