for ON-SITE WASTEWATER SYSTEM

OWNER: MAX SPEAR — APPLICATION DATE: 1/06
ADDRESS: — DATE EVALUATED: 4/06
PROPOSED FACILITY: RES — PROPOSED DESIGN FLOW (.1949): 360 GPD — PROPERTY SIZE:
LOCATION OF SITE: LOT 68 DAVIDSON WOODS — PROPERTY RECORDED: Y
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut — TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
25 A 1	L 5-10%	0-7	BSCL WR	fri SSSP SMAP	—	61"	—	—	PS .25 gpd/ft²
		7-32	RC MFABK	fri SSSP SMAP					
		32-61	RCL MWSBK	fri SSSP SMAP					
				common SAP					
25 B 2	L 5-10%	0-8	BSCL WR	fri SSSP SMAP	—	52"	—	—	PS .3 gpd/ft²
		8-24	RC MFSBK	fri SSSP SMAP					
		24-52	RCL MFWSBK	fri SSSP SMAP					
				common SAP					
25 C 3	L 5-10%	0-9	BSCL WR	fri SSSP SMAP	—	50"	—	—	PS .3 gpd/ft²
		9-27	RC MSBK	fri SSSP SMAP					
		27-50	RCL MWSBK	fri SSSP SMAP					
25 D 4	L 5-10%	0-7	BSCL WR	fri SSSP SMAP	—	55"	—	—	PS .3 gpd/ft²
		7-23	RC MFSBK	fri SSSP SMAP					
		23-55	RCL WSBK	fri SSSP SMAP					
				Many SAP Inc.					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: ROWAN SOIL & ENVIRONMENTAL SERVICES
OTHER(S) PRESENT:

COMMENTS: