IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 140115 PIN# 4722 695 036 063 DATE 8-13-07

OWNER OR APPLICANT Spear Builders PHONE: Business 704-202-4964 Home

ADDRESS 172 Allendale Cir. Troutman NC

LOCATION Old Mountain Rd N TR Buffalo Shoals TR Davidson Rd TR Winding Cedar on left

SUBDIVISION Davidson Woods BLOCK / SECTION 3 LOT 63 LOT AREA 1.78 AC SITE CLASS. PS DESIGN FLOW 360gpd L.T.A.R. .2gpd/ft2

Septic Tank: 1000 Gallons: STB 760 Date 7-20-12

Pump Tank: 1000 Gallons: PT 363 Date 1-14-13

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1350 Linear Feet 450

No Lines 3@150' Trench Width 36" Max Trench Bottom Depth 18" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% reduction pm

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons 6 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: 3" imported cover required

Comments:/Conditions:

INITIAL SITE SKETCH

See plan from Rollans Soil & Environmental Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: date 8-13-07

Authorization to Construct by: date 5-8-13

Installed by: Matt Beaver

Operation Permit by: date 6-28-13

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK