DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mtn Creek Inn / Spear Elks APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-10-04
PROPOSED FACILITY: STR PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 37 pha 2 Davidson Woods PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-24	wksbk rc	fi sl/sesp					.25 / .34
		24-36	massive l/sl sap	fr sssp					
2	5%+ S	0-9	gr brn sl/sel fr sssp						.3
		9-33	wk-m fsbk rc	fi-fr sp sap					
		33-58	wk fsbk-massive vfel	fr sssp common/sap					
3		0-6	wksbk Rbrsd	fi sss p					.25-.3
		6-36	wk m fsbk rd/cl	fi sssp sap					
		36-59	Massive l/sm	fr sssp					
4	4/5%	0-22	gr brn sl/sel	fr sssp					.3
		22-44	m-wk fsbk rc	fr sp sap					
		44-55	massive sl sap	fr sssp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	RS	RS
System Type(s)	1m25% Red	LPPPBS
Site LTAR	~.275	~.275

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): B
EVALUATED BY: DLA
OTHER(S) PRESENT: _____