Jackie Trent
Ronnie Hall

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Honeycutt DATE 7-1-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd & Kyles X Rd Tk. on old Mountain Rd Go approx 1 mile 2 Trailers on Rt S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area Acreage

Character & Porosity of Soil Red Clay
Percolation Rate Ok.
Topography Slope to back
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1375 Linear Ft. 500
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )
From Honeycutt House
Installed by Mr Honeycutt & Henry Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 7-1-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold