IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-528 1

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 153959 PIN # 4722755473 DATE 12-5-08

OWNER or APPLICANT DONALD JAMIE FREEZE PHONE: Business 704-902-1647 Home: 704-528-3789

OWNER or APPLICANT ADDRESS 646 OLD MOUNTAIN ROAD Statesville NC 28625

LOCATION / DIRECTIONS 21 SOUTH (R) OLD MTN RD PAST HIGH SCHOOL ON RT AT BOX # 646

SUBDIVISION QUAIL MEADOWS BLOCK / SECTION LOT # 3 LOT AREA 1.5 DESIGN FLOW 240 L.T.A.R. EXISTING

Septic Tank EXISTING Gallons: STB Date

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 2 Linear Feet 250'

Trench Width 36" Max. Trench Bottom Depth EXISTING Gallon Depth EXISTING

☐ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: GRAVITY CONVENTIONAL

Repair System Description: PRE 1983

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 2

☐ Business No. Persons 4

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

(1) This is a properly functioning system in use. Addition is not changing flow

(2) TANK MUST BE 5' FROM ADDITION (3) OLD SEPTIC RECORD NOT FOUND

Comments / Conditions

INITIAL SITE SKETCH

SEE ATTACHED EXISTING SYSTEM CHECK DESIGN BY LONNIE COOK, R.S.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Donald J Freeze Date 12-8-08

Improvement Permit by: Date

Authorization to Construct by: Date

Installed by:

Operation Permit by: Date:

Existing System Inspected by: Date: 12-5-08

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant