DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Contractor
~~OWNER~~: Heritage Bldg Co. APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/9/01
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .6 Ac.
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot # 1240

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	8% Linear	0-6	scl wsbk	fr sssp SESP					PS .3
		6-13	cl wsbk	fi sp SESP					
		13-35	cl w/sap m wsbk	fi sssp SESP					
		35-48	sap m wsbk	fr NS NP SENP					
2	6% Linear	0-6	scl m wsbk	fr sssp SESP					PS .4
		6-13	30% sap wsbk	fi sssp SESP					
		13-48	sap	fr NS NP NESP					
3	8% Linear	0-5	scl	fr sssp SESP					PS .3
		5-16	cl wsbk	fi sp SESP					
		16-35	cl w/sap w wsbk	fr sssp SESP					
		35-48	sap @ (58)	vfr NS NP NESP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Grnd, Conv.	Grnd, 50% Red.
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____