IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 108960 PIN# 4722781450

OWNER OR APPLICANT COOL SPRINGS BUILDERS

ADDRESS 345 OLD MOCKSVILLE RD Statesville NC 28625 PHONE: Business 704-902-9799 Home

DATE 7-1-08

LOCATION 21 SOUTH @ ONE @ Rumple Hill AT END IN CUL-DE-SAC

SUBDIVISION Lippard Springs BLOCK / SECTION 4 LOT 91 LOT AREA .82 ACRES SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. 13

Septic Tank: 1000 Gallons: STB 1017 Date 10-1-07

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet ER=1200 Linear Feet 300'

No Lines 3x100' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: GRAVITY 2540 PRODUCT

Repair System Description: LP 25'1, 2@100'1&2

Maintenance Agreement Required: ☐ Yes ☒ No

☒ Gravity ☐ Pressure

☐ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons 6 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: ① Install Lines on Contours & MAINTAIN SETBACKS

Comments:/Conditions: TOFFTile Filter & MACKER INSTALLED AS DRAWN. WELL IS 120' to septic line.

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY LORNE COOK, R.S.I.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 7-17-08

Improvement Permit by: date 7-1-08

Authorization to Construct by: date 7-1-08

Installed by: Craig Thompson Excavating Inc

Operation Permit by: date 7-18-08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

Permit # 108960

Pin # 4722781450

Lippard Springs LOT #91

1" = 40'

