DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-10-04
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 35 Phs 2 Hawkson Woods PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-12	gr lsm sd	frssso					
		12-37	wk fsbk rc/cl	fi fr sp sss so sso	few small gravelly rock		27-37"		.25-.3
		37-56	wk fsbk-massive cl/l sap	fr sso					
2	1% L	0-2	gr lsm sl	fr					
		2-22	wk m fsbk rc	fr sss so sap					.3
		22-40	(BC) wk fsbk yp cl	fr sss p	common mi sap				
		40-56	massive l sap	fr sso p					
3		0-24	wk m fsbk rc	fr sp sso					
		24-50	wk f sbk r/cl	fi sss p sap	few sap				.25-.3
4	AH 7-20-04	0-10	wk f sbk yp sl	fr sss p	few gravelly rock				
		10-41	m fsbk rc	fr sss p	few mi sap, few gravelly rock				.3
		41-48	wk f sbk yp cl	fr sss p	common mi sap				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	RS	RS
System Type(s)	CONV 25%red	LPP PBPS
LTAR	.25-.3	.25-.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: [signature]
OTHER(S) PRESENT: _____