IREDELL COUNTY HEALTH DEPARTMENT

02382

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RAY BALL DATE 11-27-84 PERMIT NO.

PHONE: Business Home

LOCATION Troutman, Farm Rd. off old Mtn. Rd., go approx. 3/4 mi., T.L. on private lane (Hugh Ball mailbox) go 100 yds on left S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.


House ( ) Mobile Home (✓) Business ( ) Other May Quilt Farm Cater.

No. Bedrooms 2-3 No. Bathrooms 1-2 Character & Porosity of Soil Prov. Suitable

Garbage Disposal Unit	Yes ( )	No (✓)	Percolation Rate	Soil Log ft	
Auto. Dishwasher	Yes ( )	No (✓)	Topography	2-6%	
Auto. Wash. Machine	Yes (✓)	No ( )	Depth to Water Table	10+	
Site Suitable	Yes (✓)	N. ( )	Rock or other impervious formations	none observed.	

Lot Area 6 acres

____ Basement with Plumbing ____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Roger Barry Sigmon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 11-27-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 2, 1989 0:51