DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: Rockwell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Todd Mason
ADDRESS: ____
APPLICANT: Todd Mason
APPLICATION DATE: 3-22-99 DATE EVALUATED: 4-5-99
PROPOSED FACILITY: 3bd House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ____
LOCATION OF SITE: 6214 Williams Farm off Callaway Rd PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 4%	0-16	SBK C	F.					PS .3
		16-36	SBK & C/ [illegible]	[illegible]					
		36+	SAP						
2	R 4%	0-16	SBK C	F.					PS .3
		16-40	SBK/S C/SBK	FR					
		40+	SAP/L						
3	L	0-12	SBK SCL/C	FR					PS .3
		12-42	SBK C/C	FI FR					
		42+	S	FR					
					TBY				
4					6 dk	40+			

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: ____
OTHER(S) PRESENT: ____