IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) ~~878-5205~~ Mooresville Office (704) 660-3625 PERMIT # 217029

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4722-96-~~7990~~-7775

APPLICANT: 46 Design Build | APPLICANT ADDRESS: P.O. Box 60 Troutman NC 28166

SITE ADDRESS: 1384 Charis Lane (134) Statesville, NC 28677 | PHONE: 704-578-4951 | ALT. PHONE:

SITE DIRECTIONS: Rt 21 South → Rt on Old Mtn Rd → Right on Wallace Springs → Left on Charis Lane → Lot on Right.

SUBDIVISION: — | SECTION: — | LOT #: — | LOT AREA: 10.211 acres | DESIGN FLOW: 360 gal/day | L.T.A.R.: 0.30

Septic Tank	1000 (gal)	STB	825	Date	8/24/16	☒ New System ☐ Repair ☐ Expansion	System Type: I II (III) IV V VI	☒ Residence	No. Bedrooms 3
Pump Tank	— (gal)	PT	—	Date	—	System Description:	25% Reduction (Serial distribution)	☐ Business	No. Persons 6
Pump Make	—	Model	—	Serial #	—	Repair System Description:	Same	☐ Other	No. Employees
# Nitrification Fields	1	# Lines	4	Linear Ft:	300	Maintenance Agreement Required:	☐ YES ☒ NO	☐ Slab	☒ Crawl Space
Trench Width	36"	Max. Trench Bottom Depth	18"	Gravel Depth	—	☒ GRAVITY	☐ PRESSURE	☐ Basement w/plumbing	☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: Recommend pumping septic tank every 3-5 years. Recommend consolidating access lot to Charis Lane prior to commencement of construction.

INITIAL SITE SKETCH

See attached plans by The Oaks Group [Kathleen Saunders LSS #1313]

APPROVED MAR 17 2016

AS BUILT SKETCH

Installed as Drawn by K. Saunders

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

☐ IMPROVEMENT PERMIT *with plat valid without expiration.* ☒ IMPROVEMENT PERMIT *with site plan valid for 60 mos.* ☒ AUTHORIZATION TO CONSTRUCT *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Erma Allen Date: 3/21/16 Installed by: Rowan Septic Tank

IMPROVEMENT PERMIT by: Tom Haught Date: 3-17-2016 OPERATION PERMIT by: W Sparks Date: 11/8/16

AUTHORIZATION TO CONSTRUCT by: Dave Flynn Date: 06/27/16 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

1/2" EIR

914.49'

560'

493'

N

1" = 50'

APPROVED MAR 1 7 2016

150'

137'

Drive follows old Road beds

Well

N 33°16'29"E 541.90'

GULLY

GULLY

Lot contains 10.3

House

702

20

D

15'

150' Repair

150' Repair

C

P

O

B

85'

15'

B

R 30' ✓

O 85'

P

50' ✓

Fill Gully

15'

15'

Top of cut for Logging Rd

* Septic Area requires some shaping