CI

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 133556 PIN# 4722 96 3813 73070 DATE 2-24-06

OWNER OR APPLICANT RANDALL MYERS PHONE: Business 704-902-3199 Home 704-878-0616

ADDRESS 3973 TAYLORSVILLE HWY Statesville NC 28677

LOCATION 21 SOUTH (R) 00 mtn RD (R) WAMPLE SPRINGS (L) CHARLES ON RT

SUBDIVISION Williams Farm BLOCK / SECTION III LOT 42+42A LOT AREA .868+.434=1.446 SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1000 Date 2-27-06
Pump Tank: ____ Gallons; PT ____ Date ____
Pump Make: ____ Model ____ Serial No. ____
Nitrification Field: No Fields 1 Square Feet EQ/1200' Lingar Feet 300'
No Lines 6X50 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: GRAVITY 25% REDUCT
Repair System Description: GRAVITY 50% REDUCT
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 3 No. Persons 6 No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth N/A ☒ Gravity ☐ Pressure ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions: (1) INSTALL LINES ON CONTOURS. INSTALL 6 LINES, 50 LONG, USE 6 1 FLOW DIVIDER TEE AND 3 EFFLUENT SPLITTERS SUCH AS ZOELLER TRU FLOW SPLITTER. (2) NOTE ALL THE SETBACKS. MINIMUM SETBACKS (3) BUILDER WANTS TO SLIDE HOUSE FRONT CORNER (which is 40' OFF P/L) UP 5'. HOUSE FRONT CORNER (which is 80' off P/L) will not move. This is OK as long as the well is 25' from HOUSE. Well is 100' from 2 SEPTIC SYSTEMS. (4) IF SETBACKS from system & GULLY CAN NOT BE MAINTAINED, then ~~the~~ gully will have to be filled & packed before Operation Permit CAN BE ISSUED.

- ST IS 100' from METHODIST WELL TO EAST
- ST IS DRAWN AS INSTALLED AND IS 120' from POTENTIAL WELL SITE

INSTALLED AS DRAWN

INSTALL LINES AT 36" TRENCH BOTTOM

INITIAL SITE SKETCH/1" = 50'

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 2-24-06 Installed by: BILL ADAMS

Improvement Permit by: [signature] date 2-24-06 Operation Permit by: [signature] date 4-6-06

Authorization to Construct by: [signature] date 2-24-06 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK