T.H. Mc Adams property

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Katherine B Brady DATE 6/5/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W, T.L. on Airport Rd, T.R. on Rd #1364, trailer on left at end of road S. R. No. 1364

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area _____


Character & Porosity of Soil _____

Percolation Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations Rgass



Plot of System

Size of Tank 1,000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Sam Osteen

IMPROVEMENTS PERMIT BY _____

COMMENTS: Previously, there has been 3 mobile homes on this lot. Two mobile homes have been moved and this system is redesigned for only one mobile home

CERTIFICATE OF COMPLETION BY Andrew E Causey DATE 6/5/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold