DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Kevin Johnson OWNER/AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 3-17-99
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE: Lot #50 Spring Meadows
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring Pit ✓ Cut

PROFILE #	1945 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	1941 TEXTURE	STRUCTURE	MINERALOGY	
1	6-8% L	0-8"	scl	gr	1:1 / vfr	1941 WETNESS CONDITION - P.S.
		8"-36"	C	Sbk	1:1 / fr	1941/1956 SAPROLITE - 36"-↑
		36"-↑	saprolite			1941 RESTRICTIVE HORIZON - NA
						1941 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3
2	4-6% L	0-12"	Scl	gr	1:1 / vfr	1941 WETNESS CONDITION - P.S.
		12"-36"	SC	Sbk	1:1 / fr	1941/1956 SAPROLITE - 36"-↑
		36"-↑	saprolite			1941 RESTRICTIVE HORIZON - NA
						1941 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3
3	4-6% L	0-9"	scl	gr	1:1 / vfr	1941 WETNESS CONDITION - P.S
		9"-40"	C	Sbk	1:1 / fr	1941/1956 SAPROLITE - 40"-↑
		40"-↑	saprolite			1941 RESTRICTIVE HORIZON - NA
						1941 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3
4						1941 WETNESS CONDITION -
						1941/1956 SAPROLITE -
						1941 RESTRICTIVE HORIZON -
						1941 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1941 WETNESS CONDITION -
						1941/1956 SAPROLITE -
						1941 RESTRICTIVE HORIZON -
						1941 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (1945): P.S. SITE CLASSIFICATION (1941): P.S. SITE LONG-TERM ACCEPTANCE RATE: .3 gpd/ft²
OTHER FACTORS: (1941) SYSTEM TYPE:
EVALUATED BY: Michael J Dennis OTHER(S) PRESENT: Kevin Johnson, Roger Manuel
COMMENTS:

DRAFT

0125