DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Wake

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Tracy / Matt Dagenhart APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: Nov 3 99
PROPOSED FACILITY: 3 Bdrm House PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: 5th off NC Rd (2) Spring Meadow (3) Wimington Trail on Right PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 8 15%	0 8	SUB CL	FR					PS .3
		8 30	SAB CL	FR					
		30 36	SAB C/SCL	FR					
		36+	SAP Loamy	VFR					
2	L 15-18%	0 8	SUB CL	FR					PS .3
		8 36	SAB C	FR					
		36-48	SAB C Sandy	FR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946): 5
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___