HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Debbie Davidson OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 9-21-93
PROPOSED FACILITY: Sngle family dwelling.
PROPERTY SIZE:
LOCATION OF SITE: Airport Rd. Brittain Hills S/D Lot #1
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	3-5% L	0-4"	cl	gr.	1:1 / vfr	1942 WETNESS CONDITION - S
		4"-48"	C	sbk	1:1 / fr	1943/1956 SAPROLITE - NA
						1944 RESTRICTIVE HORIZON - NA
						1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
2	3-5% L	0"-5"	cl	gr	1:1 / vfr	1942 WETNESS CONDITION - S
		5"-48"	C	sbk	1:1 / fr	1943/1956 SAPROLITE - NA
						1944 RESTRICTIVE HORIZON - NA
						1948 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .35
3						1942 WETNESS CONDITION -
						1943/1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						1942 WETNESS CONDITION -
						1943/1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1942 WETNESS CONDITION -
						1943/1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: Michael G. Denard OTHER(S) PRESENT: Billy Ellenburg.
COMMENTS:

DRAFT