10381.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR LAKEWOOD GOLF CLUBHOUSE DATE 10-11-89 PERMIT NO 6D-A-4.

PHONE: Business _____ Home _____

LOCATION Airport Rd. off Hwy 70 W-1/2 mi on R. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other Remodeling house to form clubhouse.

No. Bedrooms _____ No. Bathrooms 2 Character & Porosity of Soil Sandy & suitable

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate _____


Auto. Dishwasher Yes ( ) No (✓) Topography Level

Auto. Wash. Machine Yes ( ) No (✓) Depth to Water Table _____

Site Suitable Yes (✓) No ( ) Rock or other impervious formations None observed

Lot Area Ample.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Lineal Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 10-11-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold