DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ____ OF ____

PROPERTY I.D.#: ____
DATE: ____
COUNTY: ____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Bud Nash
ADDRESS: ____

OWNER ___ AGENT: ___ PHONE: ____
APPLICATION DATE: ____ DATE EVALUATED ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____

LOCATION OF SITE: Lot 46 + 45
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS	
1	690	0 to 4	L	GR				.1942 Wetness Cond. -	N/A
		4 to 30	C	SBK	1:1			.1943 Depth/.1956 Sapr. -	W/A
		30 to 48	CL	weak SBK	1:1			.1944 Restrictive Hori. -	N/A
								.1948 Profile Class. -	PS
								Profile LTAR -	.3
2	690	0 to 4	L	GR				.1942 Wetness Cond. -	NA
		4 to 18	C	SBK	1:1			.1943 Depth/.1956 Sapr. -	24
		18 to 24	B/C					.1944 Restrictive Hori. -	
		24+	Saprolite (Foam Texture)					.1948 Profile Class. -	PS
								Profile LTAR -	.3
3	690	0 to 4	L	GR				.1942 Wetness Cond. -	N/A
		4 to 12	C	SBK	1:1			.1943 Depth/.1956 Sapr. -	18
		12 to 18	B/C					.1944 Restrictive Hori. -	N/A
		18"+	L	GR	1:1 (Saprolite)			.1948 Profile Class. -	PS
								Profile LTAR -	.3
4	1090	0 to 6	L	GR				.1942 Wetness Cond. -	N/A
		6 to 18	C	SBK	1:1			.1943 Depth/.1956 Sapr. -	24"
		18 to 24	B/C					.1944 Restrictive Hori. -	N/A
		24+	L	GR	1:1 (Saprolite)			.1948 Profile Class. -	PS
								Profile LTAR -	.3

AVAILABLE SPACE (.1945) yes OTHER FACTORS (.1946) ____ SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .3

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Bud Nash

COMMENTS: ____