DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

(2)

PROPERTY I.D.#: _____ SHEET ____ OF ____
DATE: 9-1-95
COUNTY: Tidell

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Danny Lippard
ADDRESS: _____
OWNER ___ AGENT: ___ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED 9-1-95
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE: _____

LOCATION OF SITE Lot #55 Glen Ridge S/D
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (1) TEXTURE	(2) STRUCTURE	(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	4-6%	0-4"	sl	gr	I:I / fr			.1942 Wetness Cond. - 5
	L	4"-25"	C	Abk	I:I / fi			.1943 Depth/.1956 Sapr. - NA
		25"-38"	weathered Rock/c		sf			.1944 Restrictive Hori. - 25" M
								.1948 Profile Class. - U
								Profile LTAR -
2	4-6%	0-5"	sl	vsbk	I:I / fr			.1942 Wetness Cond. - 5
	L	5"-37"	C	Abk	I:I / fi			.1943 Depth/.1956 Sapr. - 42" P.S
		37"-42"	C/sap.	Abk/m	I:I / fi			.1944 Restrictive Hori. - NA
		42"+	Sap.	m	sf			.1948 Profile Class. - P.S
								Profile LTAR - .3
3	4-6%	0-6"	sl	vsbk	I:I / fr			.1942 Wetness Cond. - 5
	L	6"-38"	C	Abk	I:I / fi			.1943 Depth/.1956 Sapr. - NA
		38"+	C/weathered Rock	Abk/m	vfi			.1944 Restrictive Hori. - 36" P.S
								.1948 Profile Class. - P.S
								Profile LTAR - .3
4	4-6%	0-5"	sl	vsbk	I:I / fr			.1942 Wetness Cond. - 5
	L	5"-23"	C	Abk	I:I / fi			.1943 Depth/.1956 Sapr. - NA
		23"+	C/weathered Rock	m	vfi			.1944 Restrictive Hori. - 23" U
								.1948 Profile Class. - U
								Profile LTAR -

AVAILABLE SPACE (.1945): _____ OTHER FACTORS (.1945): _____ SITE CLASSIFICATION (.1948): U.

SYSTEM TYPE _____ LONG-TERM ACCEPTANCE RATE(S) _____

EVALUATED BY: Michael O Dennis OTHER(S) PRESENT: _____

COMMENTS: Revaluate again in diff location