15876 46395

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Hope Bros. Builders DATE 4-12-93 PERMIT NO. 6E-17-A-31

PHONE: Business 872-4111 Home

LOCATION Airport Rd. TR Parker Lake Loop TL 2nd entrance Lakewood Dr. 1st Lot on L S.R. No.

SUBDIVISION NAME Lakewood Estates LOT NO. 31 SECTION OR BLOCK NO.

House ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☐ No ☑

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ≥.5 acre

Soil Characteristics P.S. Clay


Application Rate .35 gpd/ft²

Topography 4-6% L

Depth to Water Table >4'

Rock or other impervious formations NA

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 (11-18-92) Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1065 Linear Ft. 355'

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑ county water

Installed by Hope Bros.

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Mike Dennis / Steve Hedrick

COMMENTS 100% Repair (pump to conventional)

Keep water line 10' from any part of septic system.

CERTIFICATE OF COMPLETION BY Michael L. Dennis DATE 4-12-93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold