HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Robert Parsons OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: ____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	linear 6 to 10%	0 to 6"	L	GR		.1942 WETNES CONDITION - N/A
		6 to 24	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		24 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	linear 10%	0 to 6	L	GR		.1942 WETNES CONDITION - N/A
		6 to 32	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		32 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) ____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: P.C. Moore OTHER(S) PRESENT: Mrs Robert Parsons
COMMENTS: ____

DRAFT

0 0 1 4 3