HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

(2)

PROPERTY I.D.#: ____ ____
PROPERTY RECORDED: ____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Allen McCary
ADDRESS: ____ OWNER: ____ AGENT: ____ PHONE: ____
APPLICATION DATE: ____ DATE EVALUATED: 11-17-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE: ____
LOCATION OF SITE: Lot # 59 Glen Ridge S/D
WATER SUPPLY: On-Site Well ✓ Comm. Well ____ Public ____ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
6	5-7% L	0-7"	ℓ	gr	1:1 / fr	.1942 WETNES CONDITION - S
		7"-49"	c	Abk ss	1:1 / fi	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
7	5-7% L	0-5"	ℓ	gr	1:1 / fr	.1942 WETNES CONDITION - S
		5"-42"	c	Abk	1:1 / fi	.1943/.1956 SAPROLITE - 42"-48" trav. P.S.
		42"-48"	c/sap	Abk/m	1:1 / fi	.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
8	3-5% L	0-7"	ℓ	gr	1:1 / fr	.1942 WETNESS CONDITION - S
		7"-40"	c	Abk	1:1 / fi	.1943/.1956 SAPROLITE - NA
		40"-48"	c	Abk ss	rotic mottling / 1:1 fi	.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .3 gpd/ft2
OTHER FACTORS(.1936) ____ SYSTEM TYPE Conventional, gravity fed
EVALUATED BY: Mitchell Owens OTHER(S) PRESENT: Allen McCary
COMMENTS: ____

DRAFT