HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Woodrow Clark Const. OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 3-30-99
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE: Glen Ridge S/D Lot # 19
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	6-8% L	0-4"	l	gr	1:1/ vfr	.1942 WETNES CONDITION	P.S.
		4"-48"	C	sbk	1:1/ fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
2	6-8% L	0-3"	l	gr	1:1/ vfr	.1942 WETNES CONDITION	P.S.
		3"-38"	C	sbk	1:1/ fr	.1943/.1956 SAPROLITE	38"-↑
		38"-↑	saprolite			.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
3	6-8% L	0-5"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S.
		5"-40"	C	sbk	1:1 / fr	.1943/.1956 SAPROLITE	40"-↑
		40"-↑	Saprolite			.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) P.S SITE CLASSIFICATION (.1948): P.S SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1949): SYSTEM TYPE
EVALUATED BY: Michael S. Denny OTHER(S) PRESENT: J.C. Moore
COMMENTS:

DRAFT