HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Donna Harris OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10-10-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE: _____
LOCATION OF SITE: Lakewood Estates Lot # 11
WATER SUPPLY: On-Site Well ____ Comm. Well ____ Public ✓ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	1-3% L	0-10"	sl	gr	vfr	.1942 WETNES CONDITION	S
		10"-37"	c	sbk	fi	.1943/.1956 SAPROLITE	NA
		37"-48"	c/manganese	wsbk	fi	.1944 RESTRICTIVE HORIZON	NA
						1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
2	1-3% L	0-8"	sl	gr	vfr	1942 WETNES CONDITION	S
		8"-48"	c	sbk	fi	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
3	1-3% L	0-9"	sl	gr	vfr	.1942 WETNESS CONDITION	S
		9"-42"	c	sbk	fi	.1943/.1956 SAPROLITE	NA
		42"+	Rock			.1944 RESTRICTIVE HORIZON	42" Rock
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
4	1-3% L	0-10"	sl	gr	vfr	.1942 WETNESS CONDITION	P.S.
		10"-40"	c	sbk	fi	.1943/.1956 SAPROLITE	NA
		40"-48"	c/manganese	absk	fi	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
5	1-3% L	0-8"	sl	gr	vfr	.1942 WETNESS CONDITION	S
		8"-44"	c	sbk	fi	.1943/.1956 SAPROLITE	44"-48" clay mix
		44"-48"	c/sap.	sbk/m	fi	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) _____ SYSTEM TYPE _____
EVALUATED BY: Michael F. Dennis OTHER(S) PRESENT: _____
COMMENTS: _____

DRAFT