DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JL Hopa — APPLICANT: Tim Hinkley
ADDRESS: 1120 Buckley Rd Statesville — APPLICATION DATE: 12 Jan 99 — DATE EVALUATED: 13 Jan 99
PROPOSED FACILITY: 3 BR Dw — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: _____
LOCATION OF SITE: Lot 78 Lakewood off Hilltop Rd. — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 0-2%	0-36	SaBk C	FR					PS .3
		36-48+	SaBk L/SaCl	FR VFR					
2	L 0-2%	0-24	SaBk C	FR					PS .3
		24-48+	SaBk L/SaCl	FR VFR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	✓	✓
System Type(s)	25% Red	Conv. Trench
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature]
OTHER(S) PRESENT: T. Hinkley