IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JAMES A. BYRD DATE 5-22-84 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Buffalo Shoals Rd. - west - T. R. on Airport Rd. - ¼ mi. on (R) - enter dev. (Deerfield Estates) - 3rd lot on left. S. R. No. _____

SUBDIVISION NAME DEERFIELD ESTATES LOT NO. 3 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2-3	No. Bathrooms 1-2			Character & Porosity of Soil	Prev. Suitable
Garbage Disposal Unit	Yes ( )	No (✓)		Percolation Rate	3 gal/sq. ft.
Auto. Dishwasher	Yes ( )	No (✓)		Topography	2-6%
Auto. Wash. Machine	Yes (✓)	No ( )		Depth to Water Table	10+
Site Suitable	Yes (✓)	No ( )		Rock or other impervious formations	none observed.

Lot Area 1.25 acre



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by A-A-A Enterprises

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-22-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold